

C. 43

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6 DES MS FH 2022/3353

Dated 26/05/2022

To

The Dy. Health Officer, SDMC
Public Health Officer,
Aurobindo Marg, South Zone,
Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s Khidmat Restaurant, located at Main Road, Kalkaji New Delhi 110019


Sir,

This has reference to your MHA Portal 2022041807360 dated 18/04/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 18.05.2022 in the presence of Mr. Nityanand to verify the fire safety measures installed in the building and observed that restaurant running at ground floor only. During inspection, following points were observed:

- 1 The Second exit through kitchen, which is not permitted as per UBBL-2016.
- 2 MOEFA not provided.
- 3 Terrace level Fire fighting Pump not on auto mode.
- 4 Overhead tank capacity 5,000 ltrs provided against the required capacity of 10,000 ltrs & fire fighting tank is leaked and domestic use.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully



**(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE**

Copy to:-

1. M/s Khidmat Restaurant, located at Main Road, Kalkaji New Delhi 110019
2. The Joint Commissioner of Police, Lic/Branch, 1st Floor, P S Defence Colony, New Delhi -110049. For taking necessary action on the matter.