

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2022/SZ/375

Dated 03/06/2022

To

The Dy. Health Officer, SDMC,  
Public Health Department,  
Aurobindo Marg, South Zone,  
Green Park, Delhi- 110016.

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s Mamagoto (A Unit of Azure Hospitality Pvt Ltd) located at First Floor, Flat No 53, Khan Market, New Delhi 110003


Sir,

This has reference to with MHA Portal ID 2022041406994 dated 19/04/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 28.05.2022 in the presence of Mr. Prashant (Manager) to verify the fire safety measures installed in the building and observed that the restaurant running at 1st floor of the building. During inspection, following points were observed:

- 1 There is one staircase having width of 1.0 mtr against the required two staircase having width of 1.50 mtr each respectively.
- 2 There is one exit door having width of 1.0 mtr against the required two exits having width of 1.50 mtr each respectively.
- 3 Overhead tank capacity 5,000 ltrs provided against the required capacity 20,000 ltrs.
- 4 Exit sign not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
(ATUL GARG)  
DIRECTOR

Copy to:

1. M/s Mamagoto (A Unit of Azure Hospitality Pvt Ltd) located at First Floor, Flat No 53, Khan Market, New Delhi 110003