

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.F-6/DFS/MS/School/2022/ 291

Dated 07/06/2022

To

The Principal
M.C. Primary Boys/Girls School,
Kadipur Kushak No.1 & 2, Delhi-110036.

Sub: Regarding issuance of fire safety certificate in r/o M.C. Primary Boys/Girls School located at Kadipur Kushak No.1 & 2, Delhi-110036.

Sir,

Please refer to your letter received through online e-mail dated 19.05.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 24.05.2022 to verify the fire safety arrangements provided therein as per the NBC Part 4. At the time of inspection Sh. Dharam Vir (Principal) was also present at site. As per earlier FSC issued vide letter of even no F6/DFS/MS/School/2019/1776 dated 13.09.2019 above said building was comprised of 02 blocks, ground & ground+01 upper floor only. Now the school management has constructed a new block having ground+02 upper floors and there is total 02 blocks (old block- ground +01 & new block- ground +02 upper floors only). The observations/ shortcomings noticed are as under:-

1. The width of staircases new block is provided 1.50m & 1.20m both staircase required 1.50m each and second staircase provided from ground to second floor only needs to continuous from terrace level as NBC Part 4.
2. There are total 06nos of fire extinguishers against the requirement of 12nos of ABC/CO2 fire extinguishers.
3. Hose reel hose not provided at new block.
4. MOEFA system not provided at new block.
5. Terrace level fire pumps capacity 450lpm not provided at new block.
6. Overhead fire water tank capacity 10,000ltr not provided at new block.
7. Exit signage's not provided at strategic location in the building.

Keeping in view of above, fire safety certificate cannot be considered at this stage.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.