

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/NDZ/2022/ 415

Dated:- 30.05./2022

To

The Manager  
M /S Nandi Mahadev Guest House,  
4057, 408- 409, Kaseruwalan,  
Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC in r/o M /S Nandi Mahadev Guest House at 4057, 408-409, Kaseruwalan, Pahar Ganj, New Delhi.

Sir,

This has reference to online ID No. 2022042708471 dated 27.04.22, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 18/05/2022 in the presence of **Manager** and following shortcomings were observed:-

- 1. Exhaust fans <sup>one</sup> not provided as per gazette notification dated 27.05.2019.
- 2. Fire extinguishers are due for refilling.
- 3. Hose reel nozzle found missing.
- 4. Fourth floor building plans not submitted by owner/architect.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully



(Dr. S.K. Tomar)  
Dy. Chief Fire Officer  
Delhi Fire Service



Copy to :-

- 1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi