

C-21

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2022/NDZ/ 289

Dated 06/06/2022

To.

The Principal,
National Victor Public School,
C-Block, DDA Colony, West Gorakh Park,
Shahdara, Delhi- 110032

Sub:- Regarding Issuance Fire Safety Certificate r/o National Victor Public School, C-Block,
DDA Colony, West Gorakh Park, Shahdara, Delhi- 110032.

Sir.

This is in reference to your letter No. nvps/21-22/11 dated 31/03/22 on the subject cited above. In this connection, it is to inform you that the officers concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view in presence of Mr. Sharvan Kumar (Admin.). The building comprise of basement, ground plus one upper floor. Following shortcomings were observed during the time of inspection.

1. Firefighting system (fire pump, down comer, automatic sprinkler system & hose reel) which have been provided in the building were tested/checked and found non-functional.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully


31/6/22

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

o/c e.

Copy to :-

The Director of Education,
B-Block Yamuna Vihar, Delhi-110053