

285

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2022/430

Dated: 02/06/2022

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of **M/s Noor Guest House** located at **420-21 & 25, Gali Matia Mahal, Jama Masjid, Delhi.**

Sir,


With reference to online application I.D. no. 2022032504226 dated 26.03.2022 on the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 23.05.2022 in the presence of Mr. Rizan Ahamad (Manager) and it was observed that building is comprised of Ground + 04 upper floors. During inspection, following shortcomings were observed:

1. Fire check doors are not provided required as per gazette notification dated 27.05.2019.
2. CO detectors not provided required as per gazette notification dated 27.05.2019.
3. First Aid Hose reel found non functional.
4. Fire pump found not in auto start mode.
5. Occupancy at fourth floor is not allowed as per gazette notification dated 27.05.2019.
6. Upload the sanctioned plans of the building or as built plans of the building duly signed by architect and owner/ occupier.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcoming at the earliest for further necessary action.

Yours faithfully,

  
31/5/22

**(Dr. S.K. Tomar)**  
Dy. Chief Fire Officer  
Tel: 011-23412025

**Copy to:-**

The Licensee, M/s Noor Guest House located at 420-21 & 25, Gali Matia Mahal, Jama Masjid, Delhi.