

c-36

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEWDELHI-110001**

No. F.6/DFS/MS/EH/SZ/2022/ 387

Dated : 06/06/2022

To

The Owner/Occupier,  
Qbic Cafe Restaurant ( A unit of Butter Knife Entertainment LLP),  
1/6, East Patel Nagar, New Delhi- 110008,

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s. Qbic Cafe Restaurant ( A unit of Butter Knife Entertainment LLP) located at 1/6, East Patel Nagar, New Delhi- 110008, New Delhi- 110008.

Sir,


This has reference to the MHA Portal Id 2022050909757 dated 10.05.2022, on the subject cited above. The said assembly building (Restaurant) was inspected by the officers concerned of this department from safety point of view on 23.05.2022 in presence of Sh. Virender Kumar (Manager).

During the course of inspection it has been observed that the restaurants running at ground floor of a building comprised of basement, ground plus three upper floors. Fire safety arrangements such as fire extinguishers, PA system, MOFEA, first aid hose reel etc. found provided in restaurant. However the following shortcomings have been observed:-

1. Fire Pump panel found not working on auto mode.
2. Fire pump on terrace & fire water tank on terrace could not be inspected due to staircase door found locked.

In view of the above shortcomings, fire safety certificate cannot be renewal at this stage. In the absence of fire safety certificate this restaurant is not safe from fire safety point of view. You are advised to rectify the above mention shortcomings and apply fresh for taking further necessary action.

Yours faithfully

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to:-

The Joint Commissioner of Police (Lic.), Police Station, Defence Colony, 1st floor, New Delhi- 110008.