

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001**

No. F6/DFS/MS/EH/2022/SZ/ 372

Dated: 30/05/2022

To,

The Joint Commissioner (Lic.)
1st Floor Police Defence Colony,
New Delhi.

Sub: -Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o M/s Over The Top (a venture of Infinity Hospitality) 3rd Floor, B-1/633, Janak Puri, Najafgarh road, New Delhi-110058.

Sir,

Please refer to your letter ID No. 2022032203960 dated 24/03/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the building to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Rahul Sharma (Manager) was present and it was observed that the building is comprised of basement, ground floor plus three upper floors but restaurant is running at third floor and have following shortcomings:-

1. Second staircase shall be widen up to 1.5 m.(min.)
2. Standby pump having 2280 LPM output at 60 m head and jockey pump having 180 lpm not provided.
3. Under ground water storage tank 50,000 liters provided in place of 1,00,000 liters.
4. Exits signage's are not Provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully,


(Anurag)
Director

Delhi Fire Service

9/9/22

Copy to:-

Sh.Rahul Sharma (Manager)
M/s Over The Top (a venture of Infinity Hospitality)
3rd Floor, B-1/633, Janak Puri, Najafgarh road, New Delhi-110058.