

C-17

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/School/2022/ 290

Dated 07/06/2022

To

The Principal
Rose Petals Public School,
Plot No. D-57, Gali No.02, Harit Vihar ,
Sant Nagar, Burari, Delhi-110084.

Sub: - Regarding issuance of fire safety certificate in r/o Rose Petals Public School located at Plot No. D-57, Gali No.02, Harit Vihar Sant Nagar, Burari, Delhi-110084.

Sir,

Please refer to your letter received online e-mail dated 30.04.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 24.05.2022 to verify the fire safety arrangements provided therein as per the NBC Part 4. At the time of inspection Sh. Kranti Chauhan (Care Taker) was also present at site. As per earlier FSC issued vide letter of even no F6/DFS/MS/2015/School/WZ/2254 dated 23.12.2015 above said building was comprised of ground + 02 upper floor only. Now the school management has constructed third floor on school building at present composition of building having ground+03 upper floors. The observations/ shortcomings noticed are as under:-

1. The width of staircases is provided 1.50m & 01m both staircase required 1.50m each and second staircase provided from ground to first floor only needs to continuous from terrace level as NBC Part 4.
2. There are total 04nos of fire extinguishers against the requirement of 14nos of ABC/CO2 fire extinguishers.
3. Hose reel hose found removed at site.
4. MOEFA system not provided.
5. Terrace level fire pumps capacity 450lpm found removed.
6. Overhead fire water tank capacity 10,000ltr found removed.
7. Exit signage's found removed at strategic location in the building.

Keeping in view of above, fire safety certificate cannot be considered at this stage.

Yours faithfully



(Atul Garg)
Director

Ph:-011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.