

C82

5/27/22 10:48 AM

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2022/ 94/428

Dated:-31./05./2022

To

The Manager
M/S Royal Inn Guest House,
9520, Gali No. 13, Multani Dhanda,
Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Royal Inn Guest House located at 9520, Gali No. 13, Multani Dhanda, Pahar Ganj, New Delhi.

Sir,

This has reference to online ID No. 2022043008968 dated 01/05/2022, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 20/05/2022 in the presence of **Mr. Om Hari** and following shortcomings were observed:-

1. CO Detector are not provided as per gazette notification dated 27.05.2019.
2. PA System found nonfunctional.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully


30/5/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.