

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/Banquet/WZ/2022/ 80

Dated: - 03/06/2022

To,

Sh. Pankaj Gupta,
M/s. Royal Peppar Banquet Hall,
C-94, Wazirpur Industrial Area,
Delhi-110052,

Sub:- Renewal of Fire Safety Certificate in respect of M/s. Royal Peppar Banquet Hall, located at B-70/3, Wazirpur Industrial Area, Delhi-110052

Sir,

This has reference to your online application received through MHA portal vide ID-2022042007753, on the subject cited above. In this connection it is to inform you that the above said assembly building has been inspected by the officer concerned of this department on 20.05.2022 in presence of Sh. Sanjay Sharma (Manager), to check the fire safety arrangements already provided in the building.

During the course of inspection, it was observed that the building is comprised of basement, ground plus three upper floors. Fire safety arrangements such as fire extinguishers, hose reel, detection system, underground water storage tank etc. found provided. However, following shortcomings have been observed:

1. Fire/smoke check door found removed from exit.
2. Smoke Management system in basement & upper floors found removed.
3. Hose reel hose, P.A. system, detection system, MOEFA, down comer system, yard hydrant, sprinkler system in basement & upper floors, are provided but not functional.
4. Main electric pump, standby diesel driven pump, jockey pump and terrace pump are provided but not functional.
5. Exit signage's removed at some places.

In view of above shortcomings, the application for renewal of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully,

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. The Dy. Health Officer, Keshav Puram Zone, NDMC, Public Health Department, A-1 Block Keshav Puram Zone, Delhi.