

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2022/School/295

Dated: 07/06/2022

To..

Smt. Sunita Goel (Principal),  
SDMC Primary School,  
Village Nasirpur, New Delhi – 110045.

Subject: Issuance of Fire Safety Certificate in r/o SDMC Primary School Located at village Nasirpur, New Delhi – 110045.

Sir,

Please refer to letter no Nil Dated-13/04/2022 on the subject mentioned above. In this connection it is to inform you that the new block was inspected by the officer concerned from this department on 26/05/2022 in the presence of Smt. Sunita Goel (Principal).

**During the course of inspection following shortcomings are observed.**

1. One staircase of 1.5 m found provided against required two staircases of 1.5 m clear width.
2. Width of class room door is 110 cm against required 120 cm clear width.
3. Hose reel hoses found nonfunctional.
4. Terrace pump found nonfunctional.
5. Exit Signage's found not provided.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054.