

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2022/NDZ/306

Dated 10/06/2022

To,

The Principal,
EDMC Primary School,
B-Block, Bhajanpura
Delhi-110053

Sub:- Regarding Issuance Fire Safety Certificate in r/o EDMC Primary School at B-Block, Bhajanpura Delhi-110053.

Sir,

With reference to your letter No. EDMC/EE(E)-I/SHN/2021-22/D-40 dated-02/05/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view on dated 26/05/22 in presence of Mr. Adhir Rajan Principal. The following points / shortcomings were noticed in the building which is comprised of ground plus two upper floors .

1. Width of staircases 1.50 mtr. wide not provided.
2. First Aid Hose Reels not functional.
3. A fire pump having 220 LPM provided in place 450 LPM output at 40 meters head as required.

In view of above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)
Director

Copy to:-

1. The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92
2. The Ex. Eng. (Elect.)-II,
Shahdara (North)Zone,
EDMC, Office of Executive Engineer (Elect)-II,
MCD Zonal Office Buildings, Keshav Chowk,
G.T. Road, Near Shyam Lal College.