

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/School/2022/NDZ/304

Dated 10/06/2022

To,

The Principal,
EDMC Primary School,
Harizan Basti, E-Block,
East Gokalpur, Delhi-110094.

Sub:- Regarding Issuance Fire Safety Certificate in r/o EDMC Primary School at Harizan Basti, E-Block, East Gokalpur, Delhi-110094.

Sir,

With reference to your letter No. EDMC/EE(E)-I/SHN/2021-22/D-40 dated-02/05/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view on dated 31/05/22 in presence of Mr. Vijay Pal Principal. The following points / shortcomings were noticed in the building which is comprised of ground plus two upper floors .

1. First Aid Hose Reels not functional.
2. A fire pump having 450 LPM output at 40 meters head not functional.
3. Over head tank 8,000 liter provided in place of 10,000 liter as required

In view of above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully



(Dr. S.K Tomar)
Dy. Cheif Fire Officer



Copy to:-

1. The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92
2. The Ex. Eng. (Elect.)-II,
Shahdara (North)Zone,
EDMC, Office of Executive Engineer (Elect)-II,
MCD Zonal Office Buildings, Keshav Chowk,
G.T. Road, Near Shyam Lal College.