

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE : NEW DELHI - 110001

Dated 10/06/2022

No. F6/DFS/MS/School/2022/298

To,

The Principal
Sarvodaya Kanya Vidyalaya
Magazine Road, Delhi-110054.

Sub:- Regarding issuance of fire safety certificate in r/o Sarvodaya Kanya Vidyalaya (School, I.D-1207112) located at Magazine Road, Delhi-110054.

Sir,

This has reference to your letter no. SKV/MR/2022/271 dated 27.04.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 19.05.2022 in presence of Smt. Kailash Kaur (Principal) and verify the compliance of the shortcomings/ observations already communicated by this department vide letter of even no. 1125 dated 03.05.2017 and observed that the shortcomings have not been removed so far.

Keeping in view of above, Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph. No. 011-23414250

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001

No.F6/DFS/MS/2017/ 1125

Dated 3/5/17

To

The Principal,
Sarvodaya Kanya Vidyalaya,
Magazine Road, Delhi.

Sub: Regarding renewal of FSC in r/o Sarvodaya Kanya Vidyalaya, Magazine Road, Delhi.

Sir,

Please refer to your letter No.SKV/MR/2017/362 dated 10/03/17 on the subject cited above. In this connection this is to inform you that the above mentioned premises was inspected by the officer concerned of this department on 20.04.2017 to verify the existing fire safety arrangements provided therein. During the course of inspection, it has been observed that the school building is comprised of ground + 3 upper floors. The following shortcomings were observed.

1. Fire extinguishers provided but not functional.
2. Hose reel provided but found non functional.
3. Down comer provided but found non functional.
4. Fire pump provided but found non functional.
5. Over head water tank found empty.
6. Exit signs found missing.

Keeping in view of above, "Fire Safety Certificate" to the above said building can not be considered at this stage.

Yours faithfully,



(Sunil Chowdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

The Director of Education,
Old Secretariat, Delhi-110054.

