

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/2022/302

Dated: 10/06/2022

To

The Principal,
Shakti Mandir Premwati Public School,
1024, Shakti Mandir, Daryaganj, Delhi.

Sub: - Regarding issuance of "**Fire Safety Certificate**" from fire safety point of view in r/o
Shakti Mandir Premwati Public School, 1024, Shakti Mandir, Daryaganj, Delhi.

Madam/Sir,

Please refer to your letter no. 4/SMPP/2022-11 dated 06.05.2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school premises on 30.05.2022 to verify the fire safety arrangements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education. At the time of inspection Mr. Monoj (Accountant), was present and it was observed that the school building is comprised of ground plus three upper floors and have complied the shortcomings issued vide letter no. F.6/DFS/MS/2019/708 dated 27.11.2019 except following which still exists:-

1. The school is not accessible to fire engines as approach road width is less than 06 meters.
2. The width of main staircase is 1.18 m against the requirement of width 1.5 m either an additional staircase having width not less than 0.75 m is required.

In view of above, the fire safety certificate cannot be issued. You are suggested to rectify the above said shortcoming under the intimation to this department for further course of action.

Yours faithfully,



(Dr. S.K. Tomar)
Dy. Chief Fire Officer o/c
Tel: 011-23412025

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi