

C-40

Dated: - 10/06/2022

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F6/DFS/MS/WZ/2022/BNQT/190

To,

The Joint Commissioner of Police,
Licensing Unit, 1st Floor,
Police Station, Defence Colony,
New Delhi.

Subject: Inspection report of M/s. Euphoria Banquets (A Unit of Unicorn Clebrators) located at Plot No. 3, F-Block, Udyog Nagar, main Rohtak Road, Peeragarhi, Delhi-110041.

Sir,

This is in reference to online application no. 2022041707306 dated 21.04.2022 on the subject cited above. In this connection, it is to inform you that the said Banquet hall building has been inspected by the officers concerned of this department to check the functionability of fire safety arrangements on 27.05.2022 in the presence of Sh. Rajeev Nagpal (Partner).

During inspection, it has been observed that the said building is comprised of 02 Basement, Ground, Mezzanine plus 02 Upper Floors, served by 03 staircases. The Fire safety arrangement such as fire extinguisher, first aid hose reel, automatic fire detection & alarming system, MOEFA, Internal Hydrant, Yard hydrant, fire pumps, overhead water tank & Underground water tank etc. found provided. However, the following shortcomings were observed:-

1. Fire check door found removed at some places.
2. Smoke Management System in basement floor found non-functional & at upper floors found removed.
3. Diesel driven pump capacity 2280 LPM is replaced by electrical pump.
4. Lift for passenger & Service leading to the basement to be closed with brick wall or to be protected lift lobby providing Fire check door.
5. Pressurization system in lift car and lift lobby found non-functional.
6. Bridal room & office room constructed with flammable ply board at basement (-1) to be removed.

In view of the above shortcoming, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. The Dy. Health Officer, Keshav Puram Zone, NDMC, Public Health Department, A-1 Block Keshav Puram Zone, Delhi.
2. Sh. Gopal Kumar, M/s. Euphoria Banquet, Plot no. 3, F-Block, Udyog Nagar main rohtak road, Peeragarhi, Delhi-110041.