

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/NDZ/2022/ 1389

Dated: 14.06.2022

To

Sh. Nitesh Garg,
German Homoeopathic Distributors Pvt. Ltd.,
Plot No. 144, FIE, Patparganj Industrial area, Delhi-92.

Subject:- Regarding grant of Fire Safety Certificate in r/o German Homoeopathic Distributors Pvt. Ltd., Plot No. 144, FIE, Patparganj Industrial area, Delhi-92.

Sir,

This has reference to your email dated 11/04/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 31/05/2022 in the presence of Mr. Kamlesh Gupta and the following shortcomings were observed :-

Building comprised of Basement, Stilt, Ground + 02 upper floors

1. one staircase width of 1.25 meter & one MS ramp 1.0 mtr. provided against required 02 nos. staircase of width 1.5 meter each as per guidelines issued.
2. Exit doors width of 1.20 to 1.25 meter provided against required width of 1.5 meter each.
3. Manually Operated Fire Alarm System not functional.
4. Fire pumps one electric and one diesel (stand by) capacity of 2280 LPM and one Jockey Pump of capacity 180 LPM not provided.
5. Overhead fire pump 450 LPM provided against required capacity of 900 LPM.
6. Fire check door of 2hr rating is not provided.
7. Smoke management system is not provided.
8. Hydrant not provided on upper floors.
9. Signage and Lift Signage are not provided.
10. Underground water tank capacity of 1,00,000 liters not provided.
11. Overhead water tank capacity of 10,000 liters provided against required capacity of 20,000 liters.
12. Standby power supply is not provided.
13. Stilt floor found converted into offices and store.

Hence, renewal of Fire Safety Certificate can not be considered at this stage.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Atul Garg