

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No. F6/DFS/MS/School/2022/NDZ/314

Dated 14/06/2022

To,

The Principal,  
MCD Primary School,  
Karawal Nagar,  
Delhi-110094

Sub:- Regarding Issuance of Fire Safety Certificate in r/o MCD Primary School at Karawal Nagar, Delhi 110094.

Sir,

With reference to your email letter No. EDMC/EE(E)-I/SHN/2021-22/D-40 dated-02/05/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view in presence of Mr. Bhopender (Principal). During the course of inspection the following points / shortcomings were noticed in the school building which is comprised of ground plus two upper floors & Ground plus one upper floor interconnect.

1. The width of the staircase 1.50 meters wide are not provided.
2. First-Aid hose reels 01 number provided in place of 02 numbers as required.
3. A terrace pump having 450 LPM output at 40 meters head not functional.

In view of above, the school building cannot be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)  
Director

Copy to:-

1. The Director of Education, EDMC  
Udyog Sadan, Plot No. 419, FIE,  
Patparganj, Delhi 92
2. The Ex. Eng. (Elect.)-II,  
Shahdara (North)Zone,  
EDMC, Office of Executive Engineer (Elect)-II,  
MCD Zonal Office Buildings, Keshav Chowk,  
G.T. Road, Near Shyam Lal College.