

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/2022/1394

Dated: 11.06.2022

To,

Sh. Dharmesh Sharma
Principal District & Sessions Judges (New Delhi District)
Patiala House Courts, New Delhi.

Sub: - Fire safety measures in New Delhi District, Patiala House Courts complex.

Sir,

This is reference to your letter no. 5673/Pr.D&Sj/PHC/NDD/2022/2022 dated 20.05.2022. In this regards it is to inform you that this is a low rise business building and business building having height less than 15 meter and less than ground plus four upper does not come under the purview of Delhi Fire Service as per DFS Act 2007 & Rules -2010. Accordingly, Fire safety certificate is not required to be issued from this department. This has already been informed vide this department letter No. F6/DFS/MS/2017/2718 dated 09.11.2017(copy enclosed).

However, the site was visited by officer concerned of this department on dated 01.06.2022 in presence of Mr. Santosh (care taker) and following points are required to be ensured.

1. Fire fighting system installed / available in the complex must be kept in good working condition as seen during the inspection. Further, hose reel & hydrants are required to be extended near to lock up rooms area also.
2. All exits doors / exit gates and corridors shall be kept clear (free of any hindrance) for speedy and hassle-free evacuation.
3. Unauthorized encroachment must be removed for approach of fire emergency vehicle for speedy rescue/ fire fighting operation.
4. Trained fire personnel shall always be available in court complex to operate the existing fire arrangements in case of emergency.

Encl: As above.

Yours faithfully


10/6/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

L