

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/NDZ/2022/ 315

Dated:- 14/06/2022

To

The Principal,
St. Mary's Sen. Ser. School,
Pocket A-2, Mayur Vihar-III, Delhi-96.

Sub: Regarding Renewal of FSC in r/o St. Mary's Sen. Ser. School, Pocket A-2, Mayur Vihar-III, Delhi-96.

Sir,

This has reference to your email dated 04/05/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 13/04/2022 in the presence of Mr. Saji Thomas (Supervisor) and the following shortcomings were observed :-

1. One hose reel may be provided in core staircase because outer hose reel are not covering whole area.

Hence, the Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcoming under the intimation to this department for further necessary action in this regard.

Yours faithfully


13/6/22

(DR. SK. TOMAR)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Dy. Director of Education,
D-Block, Anand Vihar, Delhi.

ok
mw