

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F6/DFS/MS/WZ/2022/BN&T/92

Dated: - 10/06/2022

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit,
Police Station, Defence Colony,
New Delhi.

Subj:- Regarding renewal of Fire Safety Certificate in r/o Symphony Celebration Pvt. Ltd.
Located at D-11, Udyog Nagar, Industrial Estate, Rohtak Road, Delhi-110087.

Sir,

This has reference to online application no. 2022042408162 dated 14.04.2022 on the subject cited above. In this connection, it is to inform you that the above said building has been inspected by the officer concerned of this department from fire safety point of view on 21.05.2022 in the presence of Sh. Jagdish Nagpal (Owner). During inspection, it has been observed that the said building is comprised of Basement + Ground + 02 Upper Floors only served with 03 staircases & 06 staircases in basement. The Fire safety arrangement such as first – aid hose reel, fire pumps at basement, fire extinguisher & underground water storage tank etc found provided. However, the following points have been noticed as shortcomings:-

1. Fire check door found removed in basement and upper floors.
2. Electrical panel underneath staircase shall be removed.
3. Smoke management system is provided at basement but found non-functional & at Upper floors found removed.
4. Fire pumps found non-functional.
5. Terrace pump 900 lpm found removed.
6. Overhead water storage tank capacity 10,000 ltrs. found removed.
7. Exit signages are provided but are not adequate.
8. Sprinkler & detectors system shall be extended in left out areas at ground floor.
9. LPG bank at ground floor shall be provided with fire protection system.
10. Generator room covered with fiber sheet to be replaced with metal sheet.
11. In Generator room area fire protection system found removed.
12. Rooms constructed on terrace floor to be removed or to be sealed with brick wall.
13. Temporary structure on terrace floor to be removed.
14. Transformer provided at ground floor to be protected by erecting fire resistance brick wall.


In view of the above shortcoming, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety

To be Cont.

(2)


arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. Sh. Sanjay Gupta, Symphony Celebration Pvt. Ltd. Located at D-11, Udyog Nagar, Industrial Estate, Rohtak Road, Delhi-110087.
2. The Commissioner, North Delhi Municipal Corporation, Civic Centre, Minto Road, New Delhi -110002


OC
08/06/22