

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/2022

1398

Dated 14/6/2022

To,

Sh. Anil Kumar (GM/PD),
Metro Bhawan, Fire Brigade Lane,
Barakhamba Road, New Delhi – 110001.

Sub: Regarding renewal of FSC in r/o Business building and multilevel(elevated) car parking at New Delhi Metro Station Ajmeri Gate (Airport Express line), New Delhi.

Sir,

This has reference to your letter No. DMRC/O&M/NDRU-PD/2022/01 dated 25/05/2022 & e-mail firewingblue@gmail.com dated 25.05.2022 on the subject cited above, it is to inform you that the site was inspected by the officers concerned department on 06/06/2022 in the presence of Sh. Vaibhav (Asst. Manager) & Ravinder Singh , Fire Inspector and the following shortcomings were observed:-

1. Staircase found blocked/locked and wastage/papers also dumped in staircase lobby at 6th floor.
2. Fire check doors found broken at some places.
3. Electrical shaft not sealed properly.
4. Fire Extinguishers are due for refilling.
5. Hose reel/Hydrant not covering the complete area of offices, required to be extended or installed new hose reel /hydrant.
6. PA & MOEFA found nonfunctional.
7. Lift lobby found encroached by making an office.
8. Detectors found nonfunctional and also required to be extended in left out offices.
9. Sprinklers covered with pop/false sealing and also required to be extended in left out area of offices.
10. Pressurization of Lift shaft, lobby & staircase found nonfunctional.
11. Main electric pump not in auto mode provision.
12. Lift signages found removed.

In view of above of shortcomings, the application for renewal of FSC is rejected. Therefore, you are requested to rectify the above shortcomings at the earliest under intimation to this department. Further, the occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to

1. The Chief Engineer/PD/Section, DMRC Ltd. Metro Bhawan, Fire Brigade Line, Barakhamba Road, New Delhi.