



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No. F6/DFS/MS/School/2022/NDZ/308

Dated: 14/06/2022

To,

The Principal,
EDMC Primary School,
Ankur Enclave, Karawal Nagar,
Delhi-110094.

Subject: -Regarding issuance of Fire Safety Certificate in r/o EDMC Primary School at Ankur Enclave, Karawal Nagar, Delhi-110094.

Sir,

Please refer to letter. EDMC/EE(E)-I/SHN/2021-22/D-40 dated-02/05/2022 on the subject cited above. In this regard, it is to inform you that, the inspection of the above said premises was carried out by the officer concerned of this department in presence of Mr. Akshay Kumar Yadav (Incharge) on dated 26/05/2022. During the inspection it was observed that the shortcomings as communicated earlier vide letter No. F6/DFS/MS/School/2021/NDZ/603 dated 08/11/2021 are yet to be rectified. Copy of the same is enclosed for your ready reference.

In view of the above Fire safety Certificate cannot be considered at this stage, you are once again requested to rectify the said shortcoming under intimation to this office for further consideration in the matter

Yours faithfully

(Atul Garg)
Director

Copy to:-

- 1) The Director of Education,
Udyog Sadan, Plot No.419, FIE,
Patparganj Industrial Area, Delhi-110092
- 2) The Ex. Eng. (Elect.)-II,
Shahdara (North)Zone,
EDMC, Office of Executive Engineer (Elect)-II,
MCD Zonal Office Buildings, Keshav Chowk,
G.T. Road, Near Shyam Lal College.

C. 13

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/School/2021/NDZI/ 603

Dated 08/11/2021

To,

The Principal,
EDMC Primary School,
Ankur Enclave, Karawal Nagar,
Delhi 110094

Sub:- Regarding Issuance Fire Safety Certificate in r/o E.D.M.C Primary school at Ankur Enclave, Karawal Nagar, Delhi 110094.

Sir,

With reference to your email no.nil dated 06/10/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view in presence of Mr. Akshay kumar yadav(Incharge) of the School. During the course of inspection it was observed that the following points / shortcomings were noticed in the building comprised of ground plus three upper floors.

1. The school building is not accessible for fire/emergency vehicles.

In view of above, the building can not be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully


(Atul Garg)
Director

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92

me/c