

C142

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 2022/452

Dated: 08/06/2022

To,

The Manager,
BloomRooms Guest house (Imperative hospitality Pvt ltd),
8591, Ram Nagar, Arakashan Road, Pahar Ganj,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S BloomRooms Guest house (Imperativ hospitality Pvt. Ltd) at 8591 Ram Nagar, Arakashan Road, Pahar Ganj. Online id. 2022051610384 dated 16.05.2022.

Sir,

This has reference to on line ID No. 2022051610384 dated 16.05.2022 & e-mail < amitsharma@staybloom.com dated 20.05.2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 03/06/2022 in the presence of Sh. Ashok and following shortcomings were observed: -

1. Fire Check Doors of 01 hr. fire rating on the staircase are not provided as per Gazette Notification dated 27.05.2019.
2. CO type detectors are not provided as per Gazette Notification dated 27.05.2019.

Further, there is restaurant at basement /lower ground, required to be applied separately on mha portal.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcomings for further consideration in the matter.

Yours faithfully,


8/6/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to :-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.