

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/310

Dated: 14/06/2022

To,


Dhruv Public School,  
Z-134, Prem Nagar,  
Kirari, Nangloi,  
Delhi-110086

**Sub:** Issue of FSC in r/o Dhruv Public School, Z-134, Prem Nagar, Kirari, Nangloi, Delhi-86.

Sir,

Kindly reference to online mail dated 26.05.2022, received in this department on the subject cited above. In this connection submitted the building was visited by officer on dated 31.05.2022 however, it has been observed that the shortcoming already issued by this department letter of even No. 90 dated 19.02.2021 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings already issued vide this department letter dated 19.02.2021 for further consideration in this matter.

Yours Faithfully

  
(Dhrampal Bhardwaj)  
Dy.Chief Fire Officer  
Tel;-01123414250

ou  
my

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/90  
To,

Dated: 19/02/2021

Dhruv Public School,  
Z-134, Prem Nagar,  
Kirari, Nangloi,  
Delhi-110086

**Sub:** Issue of FSC in r/o Dhruv Public School, Z-134, Prem Nagar, Kirari, Nangloi, Delhi-86.  
Sir,

Kindly reference to online mail dated 29.01.2021, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 11.02.2021, in presence of Miss. Rekha Malik (Principal) to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for issue of FSC is rejected under sub rule (4) of Rule 35 of DFS Rules-2010 due to following reason:

1. Terrace Fire pump with capacity 450 lpm provided but not working.
2. The required exit signage is not provided.
3. 2000 liters over head water capacity tank provided against the required capacity of 10,000 liters.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 you may apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

  
19/02/2021  
(Dhrampal Bhardwaj)  
Dy.Chief Fire Officer  
Tel;-01123414250

o/c  
Dy