



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2022/NDZ/ 323

Dated: 16/06/2022

To.

The Principal,
E.D.M.C. Primary School
A-Block, Meet Nagar,
Delhi-110094.

Subject: -Regarding issuance of Fire Safety Certificate in r/o E.D.M.C. Primary School,
A-Block, Meet Nagar, Delhi 110094.

Sir,

Please refer to your letter No. **EDMC/EE(E)-I/SHN/2021-22/D-40 dated-02/05/2022** on the subject cited above. In this regard, it is to inform you that, the inspection of the above said premises was carried out by the officer concerned of this department in presence of the Mr. Ashok Kumar, Principal of the school on dated 31/05/2022. During the course of inspection, the following points / shortcomings were noticed in the building which is comprised of ground plus two upper floors.

1. Access /approach road width is less than 6 meters.

In view of above, the school building cannot be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)
Director

o/c

Copy to:-

1. The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi-92
2. The Ex. Eng. (Elect.)-II,
Shahdara (North)Zone,
EDMC, Office of Executive Engineer (Elect)-II,
MCD Zonal Office Buildings, Keshav Chowk,
G.T. Road, Near Shyam Lal College.