

c97

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/NDZ/2022/GH/448

Dated: 08/06/2022

To

The Manager,
M/S Harsha International,
AK 22, AK Road, Pahar Ganj,
New Delhi.

Subject:- Online Application ID No.- 2022032404130 dated 24.03.22 in r/o M/S Harsha International at **AK 22 , AK Road, Pahar Ganj, New Delhi**

Sir,

This has a reference to online application ID No.- 2022032404130 dated 24.03.22 & e-mail <amarbansalaic@gmail.com> dated 10.05.2022 on the subject cited above. In this connection, it is to inform you that the site was visited on dated 27.05.22 by the officers concerned of this department and observed following shortcomings.

1. Only one staircase of 1.35 meter is provided against the requirement of 02 staircase of 1.5 meter each.
2. Width of corridor is 1.0 against the requirements of 1.80 meter.
3. Overhead water tank is 2500 liter against the requirements of 5000 liter.
4. Terrace pump of 225 LPM is provided against the requirements of 450 LPM.
5. No. of rooms being used using in the guest house as per building plans are not matching with the guest room filled in online application. Further, no. of room at fourth floor are not allowed (as mentioned in online application) as per gazette notification dated 27.05.2019.

Therefore, you are requested to rectify the above shortcomings and fill the correct information in Performa & resubmit the application for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Officer

Copy to :-

The Jt. Commissioner of Police (Lic),
1st Floor, Defense Colony Police Station, New Delhi.