

c 35

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/EH/NDZ/2022/383

Dated: 03.06.2022

To

The Deputy Commissioner (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi.

Subject:- Online Application ID No.- **2022041006428** in r/o **KFC (A Unit of Sapphire Foods India Pvt. Ltd.)** situated at Shop no. G-3, Ashok Nagar Metro Station, Delhi-96.


Sir,

This has a reference to online application ID No.- **2022041006428** dated 14.04.2022 received on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 30.05.2022 in the presence of Mr. Vishavnath (Manager) and no progress was seen on the observations communicated by this department vide letter no. F6/DFS/MS/EH/NDZ/2022/169 dated 08/02/2022 (photo copy enclosed).

Hence, the Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings under the intimation to this department for further necessary action in this regard.

Hence the online application is rejected.

Yours faithfully,


3/6/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

The Manager,
KFC (A Unit of Sapphire Foods India Pvt. Ltd.),
Shop no. G-3, Ashok Nagar Metro Station, Delhi-96.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

C-27

No. F.6/DFS/MS/EH/NDZ/2022/ 169

Dated: 08.02.2022

To

The Deputy Commissioner (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi.

Subject:- Online Application ID No.- **2021120527896** in r/o **KFC (A Unit of Sapphire Foods India Pvt. Ltd.** situated at Shop no. G-3, Ashok Nagar Metro Station, Delhi-96.

Sir,

This has a reference to online application ID No.- **2021120527896** dated 31.12.2021 received on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 25.01.2022 in the presence of Mr. Vishavnath (Manager) and observed that restaurant heaving following shortcomings at site.

Mezzanine floor

1. One staircase of width 1.5 mtr. provided, one additional staircase of width 1.5 mtr. is required.
2. Hose reel is not provided at mezzanine floor.
3. Hydrant is not provided at mezzanine floor.

Ground floor

4. Alternative exit of width 0.80 mtr. provided against required width of 1.5 mtr.

In addition to above the application needs correction in respect of number numbers of staircase, width of staircase, width of door, width of corridor. Accordingly, the applicant may be directed to furnish correct information and compliance of above shortcomings for further necessary action for issuance of Fire Safety Certificate.

Hence the application is rejected.

Yours faithfully,


7/02/22

(Dr. S.K. Tomar)

Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

The Manager,
KFC (A Unit of Sapphire Foods India Pvt. Ltd.,
Shop no. G-3, Ashok Nagar Metro Station, Delhi-96.