

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/2022/WZ/312

Dated: 14/06/2022

To,

The Principal,
Maxfort School,
Run by (Mohini Chandnani Charitable Trust) Sector-23,
Rohini, Delhi-110085.,

Sub: Issue of FSC in r/o Maxfort School run by (Mohini Chandnani Charitable Trust) Sector-23, Rohini, Delhi-110085.

Sir,

Kindly reference to online mail dated 04.03.2022, received in this department on the subject cited above. In this connection submitted the building was visited by officer on dated 11.05.2022 however, it has been observed that the shortcoming already issued by this department letter of even No. 49 dated 04.02.2022 (Copy enclosed) has not been complied. You are, he may be advised to submit point-wise compliance of shortcomings already issued vide this department letter dated 04.02.2022 for further consideration in this matter

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

ou
by

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/2022/WZ/49

Date: 04/02/2022

To,

The Principal,
Maxfort School,
Run by (Mohini Chandnani Charitable Trust) Sector-23,
Rohini, Delhi-110085.,

Sub-issue of FSC in r/o Maxfort School run by (Mohini Chandnani Charitable Trust) Sector-23,
Rohini, Delhi-110085.


Sir,

Kindly reference to online e-mail dated 13.12.2021 received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **17.01.2022**, in presence of **Sh. Trilok (Admin Officer)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. 6.0m road all around building is not provided.
2. FCD is not provided in staircase of additional floor.
3. Exhaust fan is not provided in basement.
4. MOEFA is not provided.
5. Terrace Fire pump with capacity 450 LPM provided against the required capacity of 900 LPM
6. 15,000 ltrs Over Head water captive tank provided against the required capacity of 25,000 ltrs.
7. Building plans on a scale of 1:100 for additional floor is required to be referred.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "1" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "1" are as under:
[http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully


(Atish Garg)

DIRECTOR

Ph: 011-23414000

OK
OK