

340

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2022/GH/456

Dated:-10.06./2022

To

The Manager
M/S **Maya Cottage Guest House**,
8633-45, Arakashan Road, Pahar Ganj,
New Delhi.

Sub: Regarding issuance of FSC in r/o M/S **Maya Cottage Guest House** located at 8633-45, Arakashan Road, Pahar Ganj, New Delhi.

Sir,

This has reference to online ID No. 2022041807395 dated 18.04.2022, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 31/05/2022 in the presence of **Manager** and observed Fire check doors are not provided at each floor as per gazette notification dated 27.05.2019.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully


8/6/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi