

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/WZ/2022/317

Dated: 16/06/2022

To

The Principal,
Shri Hanuman Sanskrit Maha Vidyalaya,
F-487/3, Raghbir Nagar,
New Delhi-110027.

Subject: - **Regarding renewal of Fire Safety Certificate in r/o Shri Hanuman Sanskrit Maha Vidyalaya, Located at F-487/3, Raghbir Nagar, New Delhi-110027.**

Sir,

Please refer to your letter no. SHMV/2022-23/41 dated 09/05/2022 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 03/06/2022 in presence of Sh. Sunil Kumar Chaudhary to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/School/WZ/2022/131 dated 23/03/2022.

The Following Shortcomings Status is:-

S. no.	Shortcomings	Status
1.	Hose reel Hose at each floor are not provided	Rectified
2.	Terrace fire pump of 450 lpm is provided but not functional.	Rectified
3.	Over Head Water storage tank capacity of 8,000 ltrs provided against requirement of 10,000 ltrs, but not exclusively for fire fighting purpose.	Not -Rectified

In addition to above following short coming were observed

1. Terrace pump is provided but not on auto mode.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy To: -

1. The Director, Directorate of Education, old secretariat, Delhi.