

C.28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2022/ 450

Dated: 08/06/2022

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/s Tara Palace** situated at **4606, Plot no. 13, Ansari Road, Darya Ganj, Delhi-06.**

Sir,

With reference to online application I.D. no. 2022042708561 dated on 28.04.2022 on the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 27.05.2022 in the presence Mr. Pawan Bindal (Owner's Brother). During inspection, following shortcomings were observed:

1. Fire check doors not provided required as per gazette notification dated 27.05.2019.
2. CO detectors not provided required as per gazette notification dated 27.05.2019.
3. Kitchen on terrace floor not allowed as per gazette notification dated 27.05.2019.
4. Occupancy at fourth floor is not allowed as per gazette notification dated 27.05.2019.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings and upload the same on MHA Portal (delehlhlic.mha.gov.in).

Yours faithfully,


8/6/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer *etc*
Tel: 011-23412025
82

Copy to:-

The Licensee, M/s Tara Palace at 4606, Plot no. 13, Ansari Road, Darya Ganj, Delhi-06.