

c 45

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 447

Dated:-08./06./2022

To,

The Manager,
M/S **Unistar Guest House**,
3380, Christian Colony, D.B.G. Road,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Unistar Guest House located at 3380, Christian Colony, D.B.G. Road, New Delhi.


Sir,

This has reference to on-line ID no. 2022042808678 dated 04.05.2022, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 30/05/2022 in the presence of manager and following shortcomings were observed:

1. Fire check doors are not provided as per gazette notification dated 27.05.2019
2. Smoke management system are not provided as per gazette notification dated 27.05.2019
3. CO type detectors are not provided as per gazette notification dated 27.05.2019.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service
✓

Copy to

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony, New Delhi.