

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No.F6/DFS/MS/School/NDZ/2022/319

Dated:- 16/06/2022

To

The Principal,
Vivekanand Public School,
B-Block, Anand Vihar, Delhi – 110092.

Sub: Regarding Renewal of FSC in r/o Vivekanand Public School located at B-Block, Anand Vihar, Delhi – 110092.

Sir,

This has reference to your no. VPS/2022/1430 dated 18/05/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 04/06/2022 in the presence of Mrs. Veena Harmani & Mr. Rajiv Jain and the following shortcomings were observed :-

1. Hose reel not functional.
2. Fire pump not functional.
3. Temporary structure/rooms constructed at terrace & ground floor to be removed.

Hence, the Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings under the intimation to this department for further necessary action in this regard.

Yours faithfully


14/6/22

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

The Dy. Director (Education),
D-Block, Anand Vihar, Delhi - 92.