

C. 60

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2022/ 484

Dated: 17/06/2022

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/S Alam Panah Royal Guest House** located at **2620-21, Bara Dari, Ballimaran, Delhi -06.**

Sir,

With reference to online application I.D. no. 2022052411095 dated 24.05.2022 on the subject cited above. It is informed that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 26.04.2022 in the presence Mr. Ikram (Owner's Brother) and it was observed that building is comprised of Ground + 04 upper floors. During inspection, following shortcomings were observed:

1. CO detectors with panel and alarm not provided required as per Gazette Notification dated 27.05.2019.
2. Public address system found not functional.
3. Occupancy at fourth floor is not allowed as per gazette notification dated 27.05.2019.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


17/6/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Tel: 011-23412025

Copy to:-

The Manager, M/S Alam Panah Royal Guest House at 2620-21, Bara Dari, Ballimaran, Delhi -06.

o/c
16/6