

926

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F 6/DFS/MS/EH/2022/SZ/ 403

Dated 14/06/2022

To

The Dy. Health Officer, SDMC,
Public Health Officer, South Zone,
Aurobindo Marg,
Green Park Delhi 110016

Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o M/s Burger King (Burger King India Ltd) at FS-9 & 10, 3rd Floor at Ambience Mall, Plot No 2, Nelson Mandela Marg, Vasant Kunj New Delhi 110070

Sir,

This has reference to with MHA Portal ID No 2022040906251 dated 14/04/2022 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 04/06/2022 in the presence of Mr. Harjeet Singh and observed that the shortcoming intimated vide letter no. F 6/DFS/MS/2021/74 dated 08/02/2021 has not been complied yet. (Copy Enclosed for ready reference)

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit. The action taken report in this concerned may also be forwarded to this department.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE

3rd

Copy to:-

1. M/s M/s Burger King (Burger King India Ltd) at FS-9 & 10, 3rd Floor at Ambience Mall, Plot No 2, Nelson Mandela Marg, Vasant Kunj New Delhi 110070

CS

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/ 2021/ 74

Dated 08/02/2021

To

The Dy Health Officer,
SDMC, South Zone,
Green Park, Delhi

Sub: - Regarding issuance of fire safety certificate in r/o M/s Burger King, (Burger King India Ltd) at FS-9 & 10, 3rd floor at Ambience Mall, Plot No. 2, Nelson Mandela Marg, Vasant Kunj, New Delhi-110070

Sir,

This has reference to your online ID No. 2020021502613 dated 15/02/2020 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 16.12.2020 in the presence of Mr. Dhiraj (Manager) to ascertain the availability and operability of fire protection and fire safety measures as installed in the building. During the course of inspection, the following shortcomings/ observations were noticed:

1. There is only one exit having width of 1.50 mtr against the requirement of two exits. The second exit with width of 2 mtr is also to be provided.

Keeping in view of above Fire Safety Certificate cannot be considered at this stage. You may apply again on form 'T' as stipulated in sub rule (2) 35 of rules, DFS Rules 2010 after compliance of the shortcoming mention above. The link for forms is as under available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.

Yours faithfully


(Atul Garg)
Director

Copy to:

1. The Authorized Signature, M/s Burger King, (Burger King India Ltd) at FS-9 & 10, 3rd floor at Ambience Mall, Plot No. 2, Nelson Mandela Marg, Vasant Kunj, New Delhi-110070