

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2022/ 1430

Dated: 16 / 06 / 2022

To,

Sh. Sumit Mani (Admin. Manager)
FEBA-INDIA, A-42-44, Manushree
Building, Dr. Mukherjee Nagar, Delhi-09.

Sub:- Regarding issuance of Fire Safety Certificate in r/o M/s FEBA-INDIA located at A-42-44, Manushree Building Commercial Complex, Dr. Mukherjee Nagar, Delhi-110009.

Sir,

Please refer to your letter no. Nil dated 18.04.2022 and received in this office vide outdoor dairy no.498 dated 18.04.2022 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 03.06.2022 to verify the fire safety arrangements installed in the building. At the time of inspection Sh. Sumit Mani (Administration manager.) was also present at site. During the course of the inspection it is observed that the building is comprised of basement, ground, mezz & three upper floors only. Your request for FSC is rejected under Sub Rule 4 of Rule 35 of Delhi Fire Service Rules, 2010 due to following observations:-

1. Fire check doors not provided.
2. Smoke ventilation fan not provided in basement.
3. Automatic fire smoke detector system not provided in the building.
4. MOEFA System not provided.
5. Public Address System not provided.
6. Sprinkler System not provided in the building.
7. Underground water tank capacity of 50,000ltr. empty and damaged condition.
8. Exit signage's and not provided at strategic location in the building.
9. Standby power supply not provided in the building.

Keeping in view of the above Fire Safety Certificate cannot be considered at this stage.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000