

95
46

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/EH/NDZ/2022/ 396

Dated: 14.06.2022

To

The Deputy Commissioner (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi.

Subject:- Online Application ID No.- **2022042207948** in r/o **Haryana Restaurant** situated at D-132,
South Ganesh Nagar, Delhi - 110092.

Sir,

This has a reference to online application ID No.- **2022042207948** dated 25.04.2022 received on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 19.05.2022 in the presence of Mr. Manish Kumar (Manager) and observed that building comprised of Ground + 03 upper floors, restaurant running at Ground floor only and following shortcomings were observed at site.

1. Hose reel not provided.
2. MOEFA not provided.
3. Fire pump capacity of 450 LPM not provided.
4. Overhead water tank capacity of 20,000 liters not provided.
5. Exit Signage not adequate.
6. Drawings provided is not matching with actual site, hence as built drawings to be uploaded on MHA portal.

In addition to above the application needs correction in respect of total number of floors, height of the building, width of staircase, width of door and width of corridor. Accordingly, the applicant may be directed to furnish correct information and compliance of above shortcomings for further necessary action for issuance of Fire Safety Certificate.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service

Copy to:-

The Manager,
Haryana Restaurant,
D-132, South Ganesh Nagar, Delhi - 110092. W.r.t ID No.- 2022042207948


Azadi Ka
Amrit Mahotsav