

C-41

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2022/ EH/893

Dated 14/06/2022

To,

The Manager,
Ignis Restaurant,
B-45, 1st floor, Connaught Place,
New Delhi - 110001.

Sub: Regarding renewal of FSC in r/o Ignis Restaurant (P.S. Enterprises) at B-45, 1st floor, Connaught Place, New Delhi. ID No. 2021112026863 dated 23.11.2021

Sir,

This has reference to your e-mail < acct.immigrant93@gmail.com dated 11.05.2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned department on 02/06/2022 in the presence of Manager and the following shortcomings are still not complied :-

1. Fire Extinguishers are due for refiling.
2. Hose reel, Sprinklers and fire pump found not functional.
3. Exit signage found inadequate.
4. Plastic sheet required to be removed wherever is used.

In view of above, the Fire Safety Certificate (FSC) cannot be issued. Therefore, you are requested to rectify the above shortcomings at the earliest and re-submit for further consideration in the matter.

Yours faithfully,


8/6/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

✓

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defence Colony Police Station, New Delhi.