

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/Banquet/WZ/2022/ 93

Dated: - 14/06/2022

To,

The Dy. Health Officer,
Karol Bagh Zone, Anand Parbat,
New Delhi.

Sub:- Renewal of Fire Safety Certificate in respect of M/s. Invitee Banquet Hall located at A-9, GF-FF, Kirti Nagar, New Delhi.

Sir,

This has reference to your online application received through MHA portal vide ID-2022042808736, on the subject cited above. In this connection, it is to inform you that the above said assembly building has been inspected by the officer concerned of this department on 26.05.2022 in presence of Sh. Tajinder Singh (Owner/Occupier), to check the fire safety arrangements already provided in the building.

During the course of inspection, it was observed that the said banquet hall is running at ground & first floor in a building is comprised of basement, ground plus three upper floors. Fire safety arrangements such as fire extinguishers, hose reel, MOEFA, PA system, down comer, terrace pumps, overhead tank capacity 15000 lts etc. found provided. However, following shortcomings have been observed:

1. Fire/smoke check door found removed from stairs and kitchen opening.
2. Overhead tank capacity 15000 lts provided against required 25,000 lts.
3. Smoke management system found removed.
4. Basement floor shall not be used for banquet hall purpose.
5. Exit signage's removed at some places.

In view of above shortcomings, the application for renewal of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully,

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. Sh. Tajinder Singh (owner/occupier), M/s. Invitee Banquet Hall, A-9, GF-FF, Kirti Nagar, New Delhi.