

46

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 471

Dated: 14/06/2022

To,

The Manager,
M/S Jai Vilas Guest House,
XV/8137 and 8139 to 41,
Multani Dhanda, Pahar Ganj,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Jai Vilas Guest House at XV/8137 and 8139 to 41, Multani Dhanda, Pahar Ganj, New Delhi. ID No.2022051810591 dated 18.05.22.

Sir,

This has reference to on line ID No 2022051810591 dated 18.05.22 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 31/05/2022 in the presence of Mr. Gourav (Owner) and following shortcomings were observed: -

1. One Staircase is not going to upto terrace level.
2. Width of corridor is 1.40 meter against the requirements of 1.8 & 1.50 meter.
3. Smoke venting arrangement is not provided as gazette notification 27.05.2019
4. First aid hose reel found nonfunctional.

Further, Civil work is also under progress. Accordingly, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
01123414000

Copy to:-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defence Colony New Delhi.