

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

C-31

No. F6/DFS/MS/EH/2022/SZ/400

Dated: 14/06/2022

To,


The Manager,
M/s Jubilant Foodworks Ltd (Dominos Pizza),
WZ-154,G-1block,Opp. metro pillar no.-680, Najafgarh
Road,Uttam Nagar, New Delhi-110059.

Sub:-Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o M/s Jubilant Food works Ltd (Dominos Pizza), WZ-154,G-1block,Opp. Metro pillar no.-680, Najafgarh Road,Uttam Nagar, New Delhi-110059.

Sir,

This has reference to your application ID No. 2022042508239 dated 25/04/2022 on the subject captioned above. In this connection, it is to inform you that the above mentioned building/premises was inspected by the officer concerned of this department on 31/05/2022 in the presence of Manager to verify the compliance of shortcoming already communicated by this department vide letter No. F6/DFS/MS/EH/2021/SZ/336 dated 09/08/2021 & F6/DFS/MS/EH/2022/SZ/45 dated 01/02/2022 and observed that shortcomings are still not rectified except point no.3 & 6. It is advised that occupancy should not be allowed till fire safety arrangements are provided in the restaurant.

Yours faithfully


(Sunil Chawdhary)
Dy.Chief Fire Officer

etc

Copy to:-

1. The Joint Commissioner of Police, Licensing Unit, First Floor, Police Station, Defence Colony, New Delhi.

(With a request to take further action as eating house does not have fire NOC)

101

C-21

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/EH/2021/SZ/336

Dated: 09/08/2021

To,

The Joint Commissioner (Lic.)
1st Floor Police Defence Colony,
New Delhi.

Sub: -Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o M/s Dilli 59 (A Unit of Aggarwal Traders) WZ-154.G-1, block, Najafgarh Road near metro pillar 680, Uttam Nagar, New Delhi.

Sir,

Please refer to your letter ID No. 2021041212818 dated 14/04/21 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the building to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Rajesh Sharma was present and it was observed that the building is comprised of Basement, stilt, upper ground, first & second floor but restaurant is running at upper ground & first floor and have following shortcomings:-

1. An additional staircase shall be provided 1.5 m wide. ✓
2. One of the exit shall be 2 m wide instead of 1.7 m in restaurant. ✓
3. Fire check door not provided. ✓
4. First aid hose reel & down comer system provided but not functional. ✓
5. Fire pump having 450 LPM provided but not functional & auto mode. ✓
6. Over head water tank 15, 000 liters provided in place of 20,000 liters. ✓
7. Exits signage's are not provided. ✓

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully


(Arul Garg)
Director
Delhi Fire Service
✓

Copy to:-

The Manager,
M/s Dilli 59 (A Unit of Aggarwal Traders) WZ-154,
G-1, block, Najafgarh Road near metro pillar 680, Uttam Nagar, New Delhi.