

DFA

C-38

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6 AFS/MS/EH/SZ/2022

152/402

Dated:

14/06/2022

To

The Joint Commissioner of Police,
Office of Joint commissioner of Police: Licensing,
1st Floor, P S Defence Colony, New Delhi.

Sub: - Regarding grant of Fire Safety Certificate in r/o **M/s Jungle Jamboree (U/o Jungjum Restaurants LLP), SF, 3Cs Mall, Lajpat Nagar New Delhi-24.**


Sir,

With reference to the online application I.D. no. 2022051210072 dated 12.05.2022 on the subject cited above, it is informed that the said restaurant was inspected by Assistant Divisional Officer (M. Road) from this department on 24.05.2022 in the presence of Sh. Sonu Bhati (Manager) and it was observed that the restaurant is running on 2nd floor of the building which is comprised of 2 Tier basement + ground + 02 upper floors. During the inspection the following shortcomings were observed:

1. Alternate exit (door) of 1.50 meters width shall be provided.
2. First aid hose reel found non functional.
3. Fire pump having capacity 450 LPM not provided at terrace.
4. Highly combustible material has been used for entire interior furnishing made of PVC artificial grass & plantation posing life risk to the occupants in case of fire. Same must be removed immediately.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Sunil Chawdhary)

Dy. Chief Fire Officer

Delhi Fire Service

Tel:-011-23414000

cc [Signature]
716

Copy to:-

The Licensee,

M/s Jungle Jamboree (U/o Jungjum Restaurants LLP), SF, 3Cs Mall, Lajpat Nagar New Delhi-24.