

421

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/EH/WZ/2022/413

Dated: 16/06/2022

To

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

Sub.: - Inspection report for issuance of Fire Safety Certificate in r/o M/s. Kaleva Foods located at WZ-4205, GF-FF, Kh. No. 354, Sant Nagar, Shakurbasti, Rani Bagh, Pitampura, New Delhi- 110034.

Sir,

Please refer to the online application No. 2022052110885 received through MHA portal on the subject cited above. In this connection, it is to inform you that the aforesaid restaurant has been inspected by the officer concerned of this department, in presence of Sh. Chittaranjan (manager) on 04.06.2022 to check the status of shortcomings issued by this department vide letter No. F6/DFS/MS/EH/WZ/2022/276 dated 31.03.2022 and status is as under: -

S No	Shortcomings	Status
1.	Overhead water storage tank capacity 20,000 lts is required.	Only 10,000 lts tank provided- NMR
2.	Terrace pump capacity 450 LPM is required.	Provided
3.	MOEFA at each floor is required.	Provided
4.	First aid hose reel hose having 30 mts length with shut off nozzle & down comer with two nos. of delivery hoses and one branch pipe are required at each floor.	Down Comer not provided
5.	Exit signages are required at the places mentioned during inspection.	Not Provided
6.	Standby power supply is required.	Not Provided

In addition of above, following shortcomings were also observed: -

7. Staircase passes through kitchen is not segregated with fire/smoke check door.
8. Haphazard use of LPG is to be restricted. The supply of LPG shall be routed through LPG bank preferably located outside ground floor.

In view of the above shortcomings, the application for grant of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite Fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(Atul Garg)  
Director

Copy to: -

1. The Deputy Health Officer, North Delhi Municipal Corporation, Keshavpuram Zone, New Delhi.
2. Sh. Naman Aggarwal, Owner/occupier, M/s. Kaleva Foods, WZ-4205, GF-FF, Kh. No. 354, Sant Nagar, Shakurbasti, Rani Bagh, Pitampura, New Delhi- 110034.