

C59

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/ 2022/482

Dated: 27.06/2022

To,

The Manager,  
M/S K.V.M International,  
4196, Bhagwati Bhawan,  
Pahar Ganj, New Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S K.V.M International, 4196, Bhagwati Bhawan, Pahar Ganj, New Delhi. ID No. 2022050309218 dated 03/05/22.**

Sir,

This has a reference to on line ID No. 2022050309218 dated 03/05/22. on the subject cited above. In this regard, it is to inform you that the site was visited by the officers concerned of this department on dated 13.06.22 in presence of Mr. Ashok and observed that the Smoke Management system & CO detector are not provided as per Gazette Notification dated 27.05.2019.

Therefore, you are requested to comply the same for further consideration in the matter.

Yours faithfully,

  
16/6/22

(Dr. S.K. Tomar)  
Dy. Chief Fire Officer  
Delhi Fire Service

✓

**Copy to :-**

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.