

C 70

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/ 2022 /483

Dated:- 17/06/2022

To,

The Manager,  
**Mahalaxmi Cottage,**  
2652, Gali No.8, Chuna Mandi,  
Pahar Ganj, New Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Mahalaxmi Cottage, 2652, Gali No.8, Chuna Mandi, Pahar Ganj, New Delhi. ID No. 2022052010740 dated 20.05.2022.**

Sir,

This has a reference to your mail id no.<arunsingh.y@gmail.com>dated 03.06.2022, on the subject cited above. In this regard, it is to inform you that the site was visited by the officers concerned of this department on dated 13.06.22 in presence of **Manager** and observed that Smoke Management System are not provided as per Gazette Notification dated 27.05.2019.

Therefore, you are requested to comply the same for further consideration in the matter.

Yours faithfully,

  
16/6/22

**(Dr. S.K.Tomar)**  
Dy. Chief Fire Officer  
Delhi Fire Service

✓

**Copy to :-**

I. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.