



925

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/2022/SZ/college/27  
To

Dated: 20/06/2022

The Executive Engineer (Bldg) HQ,  
South Delhi Municipal Corporation,  
9<sup>th</sup> Floor, Civic Centre, Minto Road,  
New Delhi 110002

Sub.-: Regarding grant of Fire Safety Certificate in r/o Muskaan Parents Association for the empowerment of persons with intellectual Disability at Plot No 3, Sector-B, Pocket-2 Vasant Kunj New Delhi

Sir,

This has reference to **Online ID 10062547 dated 10/06/2022** on the subject above. In this connection, it is to inform you that the officer concerned of this department and observed the aforesaid building in presence of Mr. Mayank Tomar (JE) & Mr. Sanjeev Arora (AE) SDMC on dated 14/06/2022 to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. The Exit door of assembly area & class room is less than of 02 mtr & 1.2 mtr respectively as per clause 7.23.2 of UBBL-2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. Muskaan Parents Association for the empowerment of persons with intellectual Disability at Plot No 3, Sector-B, Pocket-2 Vasant Kunj New Delhi