

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6 DFS/MS/EH/2022/SZ 408

Dated 14/06/2022

To

The Dy. Health Officer (South Zone)
South Delhi Municipal Corporation,
Aurobindo Marg, Green Park Zone,
Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s New Minar Restaurant, located at M-65, Ground, First & Second Floor, M-Block Market, G.K-1, New Delhi 110048


Sir,

This has reference to your MHA Portal 2022040104840 dated 27/04/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 07.06.2022 in the presence of Mr. Jitender Singh to verify the fire safety measures installed in the building and observed that restaurant running at GF, FF & SF only. During inspection, following points were observed:

- 1 MOEFA not working.
- 2 Internal hydrant found removed.
- 3 Exit Signage found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE

Copy to:-

1. The Joint Commissioner of Police, Lic/Branch, 1st Floor, P S Defence Colony, New Delhi -110049. For taking necessary action on the matter.
2. M/s New Minar Restaurant, located at M-65, Ground, First & Second Floor, M-Block Market, GK-1, New Delhi 110048