

C/26  
EFA

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO F-6 DFS/MS EH 2022 SZ/ 410

Dated: 14/06/2022

To

The Dy Health Officer, SDMC  
Public Health Officer,  
Aurobindo Marg, South Zone,  
Green Park, Delhi 110016

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s RED CHIILLI (Unit of Maag Entertainment Pvt Ltd) located at Ground floor S-15, Green Park, New Delhi 110016.

Sir,

This has reference to your MHA Portal No. 2022051910719 dated 20/05/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 07.06.2022 in the presence of Mr. Anil Sethi to verify the fire safety measures installed in the building and observed that restaurant running at ground floor only. During inspection, following points were observed:

- 1 There are two exit door having width of 1.0 mtr & 1.0 mtr against the required width of 1.50 mtr each respectively.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
**(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE**

Copy to -

1. The Joint Commissioner of Police, Lic/Branch, 1<sup>st</sup> Floor, P S Defence Colony, New Delhi -110049. For taking necessary action on the matter